REPORT NO. 98.32

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 72934
PERMIT NO.
BASIN 83

NOTICE OF INTENT NO. 89466

1. OWNER Scott Martin/Shary Payne
MAILING ADDRESS 3105 May Rose Cr Reno, Nv 89502

ADDRESS OF WELL 7455 Hwy 341 (Geiger Grade)
Reno, Nv 89511

2. WELL LOCATION SW 1/4 SW 1/4 SEC. 9 T 17N R 21 E Storey COUNTY

PERMIT NO ____ PARCEL NO 04-271-89 SUBDIVISION NAME Virginia Ranches

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Hard gray rock w/white specks		0	58	58
Med-hard purple-red rock		58	81	23
Med-hard red volcanic rock		81	140	59
Red volcanic rock w/white specks		140	178	38
Hard, red volcanic rock w/black		178		
and clear		178	317	139
Black rock with clear		317	326	9
Soft brown rock with med-hard		326		
black & clear rock		326	383	57
Gray rock with hard black specks		383		
& red streaks of med-hard rock		383	403	20
Multi-colored, med-hard, gray,		403		
brown w/black specks, clear,purple		403	697	294
Gray w/black speck & soft brown		697		
with black specks		697	756	59
More gray than blue,blue has wht		756		
to clear large specks	X	756	815	59
Hard, smooth, non-fractured rock		815		
purple w/white specks		815	840	25

Notes: Bottom of borehole full of native material.

RECEIVED 98 AUG 10 PM 12:14 STATE ENGINEER'S OFFICE

Date Started 7/29/98 Date Completed 8/6/98

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
600'	40+		

8. WELL CONSTRUCTION

Depth Drilled 840 Depth Cased 818

HOLE DIAMETER (BIT SIZE)

10 5/8 Inches 0 Feet 50 Feet
8 1/2 Inches 50 Feet 840 Feet
____ Inches ____ Feet ____ Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8	12.92	.188	+2	818

PERFORATIONS:
Type Perforation Factory Size Perforation 3/32 x 3
From 778 Feet to 798 Feet
From ____ Feet to ____ Feet
From ____ Feet to ____ Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 200'
PLACEMENT METHOD: [ ] Pumped [X] Poured
SEAL TYPE: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

GRAVEL PACKED: [X] Yes [ ] No
From 600 Feet to 818 Feet

9. WATER LEVEL
Static Water Level 204 Feet Below Land Surface
Artesian Flow ____ GPM ____ PSI
Water Temperature Cool F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua Drilling & Well Service, Inc
Address 675 Edison Way
Reno, Nv 89502
NV. CONTRACTOR'S LIC. NO 15291 DRILLER'S LIC. NO. ON SITE 1132
Signed [signature]
By driller performing actual drilling on site or contractor
Dated August 7, 1998