

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. **72972**
 Permit No. _____
 Basin **162**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **18102**

1. OWNER **George and Linda Geiser** ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS **2340 Chiquita** **2340 Chiquita**
Pahrump, NV 89048

2. LOCATION **NW 1/4 SW 1/4 Sec. 34 T 19S** N/S **R 53E** E **Nye** County
 PERMIT NO. **29-602-06** **Gerald Martine Ros.**
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown silty loam		0	12	12
brown loam		12	54	42
brown sandy loam	x	54	89	35
brown sandy loam and rock	x	89	109	20
brown sandy loam and rock	x	109	159	50
brown sandy loam	x	159	180	21

8. WELL CONSTRUCTION
 Depth Drilled **180** Feet Depth Cased **180** Feet

HOLE DIAMETER (BIT SIZE)
 From To
11 Inches **0** Feet **180** Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	180

Perforations:
 Type perforation **saw cut**
 Size perforation **.188**

From **140** feet to **180** feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal **50** Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From **50** feet to **180** feet

9. WATER LEVEL
 Static water level **54** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **cold** °F Quality **good**

Date started **11/20/98**, 19____
 Date completed **11/20/98**, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Baller <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	.5	na	.50

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Strickland Construction Co., Inc.** Contractor
 Address **2301 Winery Road, Suite 2** Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board **40277**

Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2986**

Signed *Larry Strickland*
 By driller performing actual drilling on-site or contractor
 Date **11-21-98**

