

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. **72974**
 Permit No. _____
 Basin **162**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **18090**

1. OWNER **Martin Averill** ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS **260 W. Leffner** **260 W. Leffner**
Pahrump, NV 89048

2. LOCATION **NE 1/4 NE 1/4 Sec. 28 T 19S** N/S **R 53E** E **Nye** County
 PERMIT NO. **29-881-22** **Bell Vista 3** Subdivision Name
 Issued by Water Resources Parcel No. _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown silty loam		0	8	8
brown sandy loam	x	8	39	31
brown calache		39	41	2
See next line		41	68	27
brown sandy loam and calache strings				
brown calache	x	68	90	22
brown calache	x	90	117	27
brown calache	x	117	140	23

8. WELL CONSTRUCTION
 Depth Drilled **140** Feet Depth Cased **140** Feet

HOLE DIAMETER (BIT SIZE)
 From To
11 Inches **0** Feet **140** Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	140

Perforations:
 Type perforation **sawcut**
 Size perforation **.188**

From **110** feet to **140** feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal **50** Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From **50** feet to **140** feet

Date started **11/23/98**, 19____
 Date completed **11/23/98**, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
.5	na	.50

9. WATER LEVEL
 Static water level **68** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **cold** °F Quality **good**

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Strickland Construction Co., Inc.** Contractor
 Address **2301 Winery Road, Suite 2** Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board **40277**

Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2086**

Signed *Larry Strickland*
 By driller performing actual drilling on-site or contractor
 Date **12-21-98**

