WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72975
Permit No.
Basin 162

NOTICE OF INTENT NO. 18099

1. OWNER Darrell and Angie Gardner
MAILING ADDRESS 2030 W. River Run St.
Pahrump, NV 89048

ADDRESS AT WELL LOCATION
2030 W. River Run St.

2. LOCATION SE 1/4 SE 1/4 Sec. 18 T 19S N/S R 53E E Nye County
PERMIT NO. Issued by Water Resources
29-352-05 Parcel No.
Crystalaire Estates Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown silt		0	16	16
brown sandy loam		16	61	45
grey clay		61	80	19
brown calache	x	80	98	18
brown calache	x	98	100	2
brown loam and gravel	x	100	133	33
brown loam and gravel	x	133	145	12
brown loam and gravel	x	145	152	7
brown calache and gravel	x	152	180	28

DEC 24 19

Date started 12/13/98, 19__
Date completed 12/14/98, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
.5	na	.50

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	180	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	180

Perforations:
Type perforation sawcut
Size perforation .188
From 140 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 180 feet

9. WATER LEVEL
Static water level 80 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Strickland Construction Co., Inc. Contractor
Address 2301 Winery Road, Suite 2 Contractor
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
Signed Larry Strickland
By driller performing actual drilling on-site or contractor
Date 12-21-98