WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

26000

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72988
Permit No.
Basin

NOTICE OF INTENT NO. 31490

1. OWNER JAMES & ELAINE LIETCHIER
MAILING ADDRESS P.O. BOX 11733 RENO, NV. 89510 SE 26
ADDRESS AT WELL LOCATION 2450 ARGONAUGHT ~~ST.~~ Way ~~2450~~ RENO, NV. 89506

2. LOCATION SE ¼ ~~SW~~ ¼ Sec. ~~22~~ T. ~~19~~ 22 N/S R. ~~26~~ 19 E. Washoe County

PERMIT NO. 005916 (Issued by Water Resources) | 079-460-14 (Parcel No.) | Rio Rock Estates #278 par. 3 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
D.G.		0	20	
CLAY		20	60	
D.G. w/clay		60	100	
D.G.		100	300	
Frackered Rock		300	360	

RECEIVED 97 AUG -7 AM 11:30 STATE ENGINEER'S OFFICE

Date started July 3, 1997
Date completed July 23, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
12		

8. WELL CONSTRUCTION
Depth Drilled 360 Feet Depth Cased 360 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	360 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		188	0	330
6 5/8		188	350	360

Perforations:
Type perforation FACTORY
Size perforation 2 1/8 x 1/8
From 330 feet to 350 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 20'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 20 feet to 360 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name JM Drilling (Contractor)
Address 1859 Hymer AVE (Contractor)
Sparks, NV 89431

Nevada contractor's license number issued by the State Contractor's Board 41172

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 796

Signed Ray Higginbotham (By driller performing actual drilling on site or contractor)

Date July 23, 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627