WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72990
Permit No.
Basin 71

NOTICE OF INTENT NO. 12934

1. OWNER Donnell Richards
MAILING ADDRESS P.O. Box 431
Wnmc., Nevada 89446

ADDRESS AT WELL LOCATION Corner of Youngberg Rd. & Vandieast Rd.

2. LOCATION S.W. ¼ S.W. ¼ Sec. 12 T. 34 N. N/S R. 37 E. Pershing County
PERMIT NO. (Issued by Water Resources) 9-060-4B (Parcel No.) No subdivision (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil brown		0	1	1
Gravely clay brown		1	3	2
Gravel brown, large		3	46	43
Gravely clay brown		46	80	34
Clay brown		80	103	23
Sand & gravel brown	12	103	115	12

'91 OCT -7 P1:48
STATE ENGINEERS OFFICE
RECEIVED

Date started Sept. 23, 1991
Date completed Sept. 24, 1991

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	5	2

8. WELL CONSTRUCTION
Depth Drilled 115 Feet Depth Cased 115 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	115 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	14	.188	0	115

Perforations:
Type perforation torch
Size perforation 1/8" by 5"
From 85 feet to 115 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 115 feet

9. WATER LEVEL
Static water level 28 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 54 °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name T. & R. Drilling (Contractor)
Address P.O. Box 1982 (Contractor)
Wnmca., Nevada 89446
Nevada contractor's license number issued by the State Contractor's Board 017721
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1190
Signed Thomas S. [illegible] (By driller performing actual drilling on site or contractor)
Date Oct. 3, 1991

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627