WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 72997
Permit No.
Basin 76

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 19552

1. OWNER Tim Edmonston
MAILING ADDRESS 5900 Farm Dist Rd Fernley, Nv. 89408
ADDRESS AT WELL LOCATION 5900 Farm Dist. Rd.

2. LOCATION SE ¼ SE ¼ Sec. 24 T. 20 N/S R. 25 E Lyon County
PERMIT NO. (Issued by Water Resources) Parcel No. 021-301-12 Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Cemented Sand		0'	25'	25"
Sandy Clay		25'	38'	13'
Clay		38'	49'	11'
Gravel + Sand		49'	51'	2'
Clay		51	62'	11'
Sandy Clay		62'	89'	90'
Clay		89'	95'	13'
Sandy Clay		95'	103'	8'
Sand + Thin Clay lay		103'	108	5'
Sand + small gravel		108'	111'	3'
Blue Clay		111'	112'	1

Date started July 28, 19 98
Date completed Sept. 30, 19 98

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Submersible	21	3'	3 hrs

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 6 5/8" inches Total depth 112 feet
inches
inches
Casing record:
Weight per foot Aprox 12# Thickness .188

Diameter	From	To
6 5/8" inches	0 feet	112 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement Grout
Depth of seal 100 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation Mill Sloted
Size perforation 1/8"
From 102 feet to 112 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 89' feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature 55 °F Quality high Iron

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name B & B Drilling (Contractor)
Address P.O. Box 272 Fernley Nv. 89408 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0014831
Nevada contractor's driller's number issued by the Division of Water Resources 1532
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1531
Signed W. R. Buchanan (By driller performing actual drilling on site or contractor)
Date 10-25-98

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627