

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. **73108**  
 Permit No. \_\_\_\_\_  
 Basin **1102**

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **18114**

1. OWNER **Lloyd and Tammy Yordi** ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS **3920 S. Percheron** **3920 S. Percheron**  
**Pahrump, NV 89048**

2. LOCATION **SE 1/4 SW 1/4 Sec. 35 T 20S** N/S **R 53E** E **Nye** County  
 PERMIT NO. **41-191-14** **Calvada Valley**  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED 4. PROPOSED USE 5. WELL TYPE

New Well  Replace  Recondition  Domestic  Irrigation  Test  Cable  Rotary  RVC  
 Deepen  Abandon  Other  Municipal/Industrial  Monitor  Stock  Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
brown clay		0	2	2
grey clay and calache		2	11	9
light brown clay		11	53	42
light brown calache	x	53	98	45
light brown clay	x	98	100	2
light brown calache	x	100	141	41
light brown clay	x	141	155	14

8. WELL CONSTRUCTION

Depth Drilled **155** Feet Depth Cased **155** Feet

HOLE DIAMETER (BIT SIZE)

From	To
<b>11</b> Inches	<b>0</b> Feet <b>155</b> Feet
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>6 5/8</b>	<b>3.7</b>	<b>.280</b>	<b>0</b>	<b>155</b>

Perforations:

Type perforation **sawcut**  
 Size perforation **.188**

From	To	feet
<b>120</b>	<b>155</b>	feet
_____	_____	feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal **50**  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From **50** feet to **155** feet

9. WATER LEVEL

Static water level **53** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature **cold** °F Quality **good**

Date started **12/31/98** 19\_\_\_\_  
 Date completed **12/31/98** 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M.		
<b>.5</b>	<b>na</b>	<b>.50</b>

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Strickland Construction Co., Inc.** Contractor  
 Address **2301 Winery Road, Suite 2** Contractor  
**Pahrump, NV 89048**

Nevada contractor's license number issued by the State Contractor's Board **40277**

Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2086**

Signed *Larry Strickland*  
 By driller performing actual drilling on-site or contractor  
 Date **1-10-99**

