

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
 WELL DRILLER'S REPORT

OFFICE USE ONLY  
 Log No. **73109**  
 Permit No. **162**  
 Basin **162**

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18121

1. OWNER **Vicki Golonka** ADDRESS AT WELL LOCATION **1521 W. Horn**  
 MAILING ADDRESS **1521 W. Horn**  
**Pahrump, NV 89048**

2. LOCATION **SE 1/4 NW 1/4 Sec. 17 T 20S N/S R 53E E Nye** County  
 PERMIT NO. **36-281-01** **CalVegas Ranchos UnitF**  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
See next line		0	18	18
grey clay with small strings of grey calache				
brown sandy loam		18	48	30
brown calache		48	56	8
brown sandy loam	x	56	76	20
brown calache and loam	x	76	128	52
See next line	x	128	140	12
brown sandy loam and calache strings				

8. WELL CONSTRUCTION  
 Depth Drilled **140** Feet Depth Cased **140** Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
**11** Inches **0** Feet **140** Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	140

Perforations:  
 Type perforation **saw cut**  
 Size perforation **.188**

From **110** feet to **140** feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal **50**  
 Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From **50** feet to **140** feet

9. WATER LEVEL  
 Static water level **56** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature **cold** °F Quality **good**

Date started **1/4/99** 19\_\_  
 Date completed **1/4/99** 19\_\_

7. WELL TEST DATA

TEST METHOD:	□ Bailer	□ Pump	<input checked="" type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<b>5</b>	<b>na</b>	<b>.50</b>	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Strickland Construction Co., Inc.** Contractor  
 Address **2301 Winery Road, Suite 2** Contractor  
**Pahrump, NV 89048**

Nevada contractor's license number issued by the State Contractor's Board **40277**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2086**

Signed **Larry Strickland**  
 By driller performing actual drilling on-site or contractor  
 Date **1-10-99**

