WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73156
Permit No.
Basin 49

NOTICE OF INTENT NO. 31838

1. OWNER City of Elko
MAILING ADDRESS 1755 College Ave
Elko NV 89801

ADDRESS AT WELL LOCATION approx 3½ miles S.W. of Elko

2. LOCATION SW ¼ NE ¼ Sec. 6 T. 33 (N) S R. 55 E County
PERMIT NO. Not required (Issued by Water Resources) | Parcel No. MW1 | well I.D. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sandy silt w/		0		
some cementation			10	10
clean sand - med/fine		10	15	5
clayey sand w/ silt		15	20	5
sand med/fine		20	25	5
clayey sand		25	30	5
clayey sand		30	35	5
clayey sand w/ gravel		35	45	10
lig clayey sand		45	50	5
sand, fine w/ silt		50	60	10
sand & gravel		60	80	20
clayey sand		80	85	5
sandy clay		85	100	15
fine grained gravel		100	115	15
clayey sand		115	135	20
clayey sand w/ gravel		135	150	15
muddy sandy clay		150	170	20
clayey sand	yes	170	180	10

Date started 9/23, 19 98
Date completed 9/25, 19 98

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
5-6	30	

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 1/4 Inches		0 Feet	180 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	Sch 40	PVC	0	180

Perforations:
Type perforation slotted screen
Size perforation .020
From 140 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 110
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 135 feet to 180 feet

9. WATER LEVEL
Static water level 170 feet below land surface
Artesian flow N.A. G.P.M. P.S.I.
Water temperature °F Quality fair

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Gustin Corp. (Contractor)
Address Po Box 894 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 22193
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1821
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 11/9/98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627