

OFFICE USE ONLY
 Log No. 73187
 Permit No. 91893
 Basin. Washoe

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34406

1. OWNER Logan Bailey ADDRESS AT WELL LOCATION 220 Matterhorn Blvd.
 MAILING ADDRESS 1820 Elm Crest Dr. Reno, NV 89506
 2. LOCATION SE 1/4 SE 1/4 Sec 27 T 22 R 19 E Washoe County
 PERMIT NO. N/A 079-450-4984 Parcel No. Head Rock Exp. #313 part 2 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-------------------|--------------|------|-----|------------|
| DG and Clay | | 0 | 70 | |
| Firm DG | | 70 | 110 | |
| Hard granite | | 110 | 190 | |
| Hard gray granite | | 190 | 385 | |

8. WELL CONSTRUCTION
 Depth Drilled 385 Feet Depth Cased 385 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 18 Feet
 12 1/4 Inches
 From 18 Feet To 50 Feet
 10 Inches
 From 50 Feet To 385 Feet
 8 3/4 Inches
 CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 6 5/8 | 14 | .188 | -1 | 385 |

Perforations:
 Type perforation Mill Slot
 Size perforation 1/8" x 3
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 +
 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 385 feet

9. WATER LEVEL
 Static water level 240 feet below land surface
 Artesian flow None G.P.M. None P.S.I.
 Water temperature Cool °F Quality Good

Date started June 30, 1997
 Date completed July 8, 1997

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---------|--------|-------------------------------|--------------|
| Approx. | 23 | 380 | 2hrs. |

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Miller & Sons Drilling Contractor
 Address P.O. Box 8056 Contractor
Reno, NV 89507
 Nevada contractor's license number issued by the State Contractor's Board 37915
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2067
 Signed Wayne Miller
 By driller performing actual drilling on site or contractor
 Date July 10, 1997