WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73208
Permit No.
Basin 82

NOTICE OF INTENT NO. 39667

1. OWNER ALTA GOLD
MAILING ADDRESS 1525 E. Newlands Drive #1
Fernley Nevada 89408

ADDRESS AT WELL LOCATION OLINGHOUSE MINE
MW-01

2. LOCATION SW ¼ SE ¼ Sec. 20 T. 21 N/S R. 23 E. Washoe County

PERMIT NO. M/O 1093 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☑ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☑ Air ☑ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Pulled pump + riser out of well began to drill out PVC + Bentonite couldn't get hole to clean very well because bentonite was so thickly gelled + PVC was fracturing off in big chunks called state engineer + explained that because hole was bentonited from top to start of screen could we just knock out bottom flush out gravel pack + fill screen area with bentonite + cement top he agreed				
Bentonite Grout pumped		525	20	505
Cement NEAT		20	0	20

Date started 9-2, 1998
Date completed 9-28, 1998

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

8. WELL CONSTRUCTION
Depth Drilled 525 Feet Depth Cased 515 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
14¾ Inches	0 Feet	17 Feet
10 Inches	17 Feet	515 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10½			0	20
5½			+2	465

Perforations:
Type perforation SLOT
Size perforation .020
From 465 feet to 515 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-525' Bentonite 525-20
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement 20'-0 ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Harris Exploration Drilling (Contractor)
Address 260 11 South Orange Street (Contractor)
Escondido Co. 92025
Nevada contractor's license number issued by the State Contractor's Board 0026000
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2114
Signed [signature] By driller performing actual drilling on site or contractor
Date Oct 1 1998

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627