WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73316
Permit No.
Basin 66

NOTICE OF INTENT NO. 37425

1. OWNER Pinson Mine
MAILING ADDRESS P.O. Box 129
Winnemucca NEVADA 89446-0129

ADDRESS AT WELL LOCATION In the pit at pinson mine. Golconda NEVADA

2. LOCATION SE ¼ SW ¼ Sec. 28 T. 38 N/S R. 42 E Humbolt County
PERMIT NO. 58011 (Issued by Water Resources) | well #13 (Parcel No.) | Pinson mine (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic dewater ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
well has been mined over. well is now 295 feet deep. approx.				
Trip pipe to bottom of hole Pump 49 Bags Bentonite abandonite slurry! Pull 180 feet of pipe Pump another 49 Bags of abandonite Bentonite mixture. let Bentonite stand for 2 hrs. pump 50 foot cement seal to plug casing. well plugged.				

Date started 10-30, 1997
Date completed 10-31, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 410 Feet Depth Cased 404 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
18 3/4 Inches	Feet	0 Feet	410 Feet
Inches	Feet	Feet	Feet
Inches	Feet	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12 3/4	33.38	.250	surface	295

Perforations:
Type perforation mill slot - 80 slot screen
Size perforation 1/8 - 3
From surface feet to 275 feet
From 275 - blank feet to 295 blank feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☑ No
From N/A feet to N/A feet

9. WATER LEVEL
Static water level 31 feet below land surface
Artesian flow — G.P.M. P.S.I.
Water temperature cold °F Quality fair

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EKLUND DRILLING CO (Contractor)
Address P.O. 2786 ELKO NV. 89803 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller #1759
Signed Tom Kerr (By driller performing actual drilling on site or contractor)
Date Oct 31, 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627