

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

office use only  
Log No. **73377**  
Permit No. *[Signature]*  
Basin *[Signature]*  
NOTICE OF INTENT NO **39927**  
**Route 445**  
*Reno, NV*

1. OWNER **Robert Poletto** ADDRESS AT WELL LOCATION **Route 445**  
MAILING ADDRESS **1660 Greg St**  
**Sparks, Nv 89431**  
2. Location **SW 1/4 SW 1/4 Sec 17 T 23N R 21E** Washoe County  
PERMIT NO. PARCEL NO. **077-370-15** SUBDIVISION NAME

3. WORK PERFORMED | 4. PROPOSED USE | 5. WELL TYPE  
 New Well Replace Recondition |  Domestic Irrigation Test | Cable  Rotary RVC  
Deepen Abandon Other | Municipal/Industrial Monitor Stock | Air Other  Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Tan yellow brown white fine sands.		0	59	59
Green yellow brown semi decomposed granite.		59	115	56
Brown clay with green brown yellow DG.		115	127	12
Light & dark green decomposed granie with green gray clay.		127	219	92
Hard green granite with occasional fractured zones.		219	296	77
Green white granite, hard.		296	316	20

8. WELL CONSTRUCTION

Depth Drilled	316 feet	Depth Cased	316 feet
HOLE DIAMETER (BIT SIZE)			
	From	To	
10 5/8 inches	0 feet	59 feet	
8 3/4 inches	59 feet	316 feet	
CASING SCHEDULE			
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet) To (Feet)
6 5/8	12.94	188	+1 1/2 316
Perforations::			
Type Perforation	Factory		
Size perforation	3/32 x 3"		
From 316 feet to	294 feet		
From 274 feet to	254 feet		
From feet to	feet		
From feet to	feet		
From feet to	feet		
Surface Seal	<input checked="" type="checkbox"/> YES No	Seal Type:	
Depth of Seal	58 feet	Neat Cement	
		Pumped	
		x Poured	
Gravel Packed:	<input checked="" type="checkbox"/> Yes No	Cement Grout	
From 58 feet to	316 feet	<input checked="" type="checkbox"/> Concrete Grout	

98 AUG 27 11:11:09  
 STATE OF NEVADA DIVISION OF WATER RESOURCES

9. WATER LEVEL  
Static water leve **75** feet below land surface  
Artesian flow **0** GPM **0** P.S.I.  
Water Temperature **cold** Degrees F Quality

Date started **7-23 -98**  
Date completed **7-30 -98**

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	x	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (hours)		
<b>25</b>	<b>175</b>	<b>2.5</b>		
<b>28</b>	<b>241</b>	<b>2</b>		

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name **McKay Drilling, Inc.**  
**2290 Pioneer Drive**  
**Reno, NV 89509**  
NV Contractors No. **14170**  
NV Driller's Lic (on site) **1511**  
Signed *[Signature]*  
By driller performing actual drilling on site or contractor  
Date **8-24-98**