WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73427
Permit No.
Basin

NOTICE OF INTENT NO. 37897

1. OWNER SKYLINE MOBILE HOME PARK
MAILING ADDRESS 7900 N.VIRGINIA STREET RENO, NV 89506
ADDRESS AT WELL LOCATION 7900 N. VIRGINIA ST. RENO, NV 89506

2. LOCATION NW ¼ NW ¼ Sec. 15 T 20 N/S R 19 E WASHOE County
PERMIT NO. 31287 Issued by Water Resources | HEALTH 006217 Parcel No. | SKYLINE MOBILE HOME PARK Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND, GRAVEL		0	10	10
CLAY, MINOR SAND		10	115	105
CONSOLIDATED SAND		115	120	5
ANDESITE HARD		120	130	10
BROWN SAND, ROCK		130	158	28
ANDESITE HARD		158	305	147
FRACTURED ANDESITE		305	338	33
GRAY FRACTURED VOLCANIC		338	460	122
HARD GRAY VOLCANIC		460	476	16
GRAY FRACTURED VOLCANIC		476	601	125

Date started SEPTEMBER 17, 19 98
Date completed OCTOBER 9, 19 98

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100	50	3

8. WELL CONSTRUCTION
Depth Drilled 601 Feet Depth Cased 600 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
17½ Inches		0 Feet	20 Feet
12¼ Inches		20 Feet	601 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	22.36	.250	+2	320

Perforations:
Type perforation WIRE WRAPSCREEN 50 SLOT
Size perforation SINGLE PERF 3/32 SLOT
From 320 feet to 340 feet
From 340 feet to 420 feet
From 420 feet to 460 feet
From 460 feet to 560 feet
From 560 feet to 600 feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No CEMENT PLUG 601'
From 100 feet to 601 feet

9. WATER LEVEL
Static water level 320 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SARGENT IRRIGATION COMPANY (Contractor)
Address 9955 NORTH VIRGINIA STREET (Contractor)
RENO, NEVADA 89506
Nevada contractor's license number issued by the State Contractor's Board 0021246
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1789
Signed (By driller performing actual drilling on site or contractor)
Date OCTOBER 9, 1998

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627