

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Permit No. 73438
 Basin 88
 NOTICE OF INTENT NO. 38016

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

1. OWNER Kevin McInerny, Loadstar Financial Group ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 18124 Wedge Pkwy #504 3600 Joy Lake Rd.
Reno, NV 89511

2. LOCATION SE 1/4 SE 1/4 Sec. 10 T 17N N/S R 19E E Washoe County
 PERMIT NO. WzCo#5987 047-010-03
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown DG		0	8	8
Brn fine sand		8	15	7
Brn clay		15	20	5
Decomposed Granite		20	35	15
DG w/ brn clay		35	45	10
DG w/ orange clay		45	50	5
Frac Decomposed granite		50	55	5
Mul colored grvls & crs sand		55	65	10
See next line		65	85	20
Cobled grvls & crs sand w/brn clay				
Frac/ DG		85	87	2
Frac granite		87	91	4
Granite w/brn clay		91	100	9
Grvls & crs sand w/brn clay		100	125	25
Coarse sand w/brown clay		125	155	30
Granite-hard		155	158	3
Brn clay		158	165	7
Granite w/hard coarse sand		165	175	10
Granite w/brown clay		175	220	45
See next line		220	240	20
Coarse sand & grvls w/ brn clay				
Frac granite	x	240	295	55

8. WELL CONSTRUCTION
 Depth Drilled 295 Feet Depth Cased 295 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 inches 0 Feet 105 Feet
8 1/2 inches 105 Feet 295 Feet
 _____ inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>+1</u>	<u>295</u>

Perforations:
 Type perforation Factory
 Size perforation 3/32 x 3"
 From 275 feet to 295 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 105' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 105 feet to 295 feet

9. WATER LEVEL
 Static water level 160 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Bruce MacKay Pump & Well Service, Inc. Contractor
 Address 1600 Mt. Rose Hwy Contractor
RENO, NV 89511
 Nevada contractor's license number issued by the State Contractor's Board 23096
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
 Signed R. Bruce MacKay
 By driller performing actual drilling on-site or contractor
 Date 8-25-98

Date started 8/10/98, 19____
 Date completed 8/13/98, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>		<u>3 hrs</u>

RECEIVED
 DIVISION OF WATER RESOURCES
 AUG 25 1998