WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 7349
Permit No.
Basin FS 107

NOTICE OF INTENT NO. 34486

1. OWNER M. HAACKENSON
MAILING ADDRESS BOX 1936
MINDEN, NV 89423

ADDRESS AT WELL LOCATION 79 CINDY COURT
SMITH VALLEY, NV

2. LOCATION NW ¼ NE ¼ Sec. 35 T. 12 N/S R. 23 E/W LYON County
PERMIT NO. 66727/60720 (Issued by Water Resources) 010 014 113 (Parcel No.) NA (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [X] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY LOAM, SOME		0	42	42
DG. COULD BE				
OLD DUNE.				
LIGHT BROWN SAND	X	42	85	43
W V FEW GRVL &				
SML COBBLES				
LT GRY SAND W	X	85	145	60
SOME GRY CLAY				
LARGER GRY SAND	X	145	186	41
FEW GRVLS				
SANDY GRY CLAY		186	205	19
SOLID GRY CLAY		205	355	130
V LITTLE SAND				
LARGE SAND &	X	355	381	26
SMALL GRVL				
DARK GRY CLAY		381	402	21
LITTLE SAND				
SMALL SAND & SMALL	X	402	439	37
GRVL				
SOLID GRY CLAY		439	460	41
V LITTLE SAND				

Date started 11/25, 1996
Date completed 12/12, 1996

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
250		4

8. WELL CONSTRUCTION
Depth Drilled 460 Feet Depth Cased 460 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
14 3/4	0	460

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 3/8		.188	+2	460

Perforations:
Type perforation SAWCUT
Size perforation 3X3/32
From 140 feet to 180 feet
From 360 feet to 380 feet
From 400 feet to 440 feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 460 feet

9. WATER LEVEL
Static water level 15 feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name NEVADA DRILLING, INC (Contractor)
Address 75 LEWERS CRK RD (Contractor)
CARSON CITY, NV 89704
Nevada contractor's license number issued by the State Contractor's Board 13697A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed Joe Reisch (By driller performing actual drilling on site or contractor)
Date 1/21/97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627