

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 73467  
 Permit No. 105  
 Basin

NOTICE OF INTENT NO. 38837

1. OWNER Rick Decarlo Custom Homes  
 MAILING ADDRESS P.O. Box 2844 Minden NV 89423  
 ADDRESS AT WELL LOCATION 770 Parmen Gardnerville W. 89410  
 2. LOCATION N6 1/4 SW 1/4 Sec. 36 T. 12 S. R. 19 E Douglas County  
 PERMIT NO. 19-440-07  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Course DC Sands and Cabbles</u>		<u>0</u>	<u>18</u>	<u>18</u>
<u>DC Sand and Cabbles</u>		<u>18</u>	<u>38</u>	<u>20</u>
<u>Void Hard Granite</u>		<u>38</u>	<u>100</u>	<u>62</u>
<u>Fractured Hard Granite</u>	<u>X</u>	<u>100</u>	<u>135</u>	<u>35</u>
<u>Soft fractures of G Sands and Clay Zones</u>	<u>XXX</u>	<u>135</u>	<u>150</u>	<u>15</u>

8. WELL CONSTRUCTION  
 Depth Drilled 150 Feet Depth Cased 150 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 3/4 Inches To 150 Feet  
 Inches Feet Feet  
 Inches Feet Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>150</u>

Perforations:  
 Type perforation Mill slot  
 Size perforation 3 x 3/32  
 From 130 feet to 150 feet  
 From feet to feet  
 From feet to feet  
 From feet to feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100 feet to 150 feet

9. WATER LEVEL  
 Static water level 40 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 35+ P.S.I.  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Capital City Well Drilling  
 Address 20 Kit Kat Dr. Carson City NV 89706  
 Nevada contractor's license number issued by the State Contractor's Board 41775  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905  
 Signed Michael Haek  
 By driller performing actual drilling on site or contractor  
 Date 8-28-98

Date started 8-26, 1998  
 Date completed 8-28, 1998

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>35+</u>	<u>35</u>	<u>2 HRS</u>	