

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37960

1. OWNER ROUND MOUNTAIN GOLD CORP. ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS PO BOX 480 MINESITE AT BOTTOM OF PIT  
ROUND MOUNTAIN NEVADA 89045  
 2. LOCATION NW 1/4 NE 1/4 Sec. 30 T. 10 N/S R. 44 E. NYE County \_\_\_\_\_  
 PERMIT NO. M10-1172 MINE WELL # 98-1  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>POORLY WEIDED RHYOLITE TUFF</u>		<u>0</u>	<u>260</u>	<u>260</u>
<u>DENSELY WEIDED RHYOLITE TUFF</u>	<u>X</u>	<u>260</u>	<u>625</u>	<u>365</u>
<u>QUARTZITE</u>	<u>X</u>	<u>625</u>	<u>650</u>	<u>25</u>
<u>QUARTZITE &amp; RHYOLITE MINED</u>		<u>650</u>	<u>695</u>	<u>45</u>
<u>QUARTZITE</u>	<u>X</u>	<u>695</u>	<u>735</u>	<u>40</u>
<u>RYOLITE</u>		<u>735</u>	<u>750</u>	<u>15</u>
<u>RYOLITE WITH QUARTZ</u>		<u>750</u>	<u>800</u>	<u>50</u>
<u>CLAY SUEINS</u>				

8. WELL CONSTRUCTION  
 Depth Drilled 800 Feet Depth Cased 800 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 50 Feet  
6" Inches 50 Feet 800 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>	<u>3.653</u>	<u>.154</u>	<u>72</u>	<u>800</u>
<u>6.625</u>	<u>12.9</u>	<u>.189</u>	<u>72</u>	<u>50</u>

Perforations:  
 Type perforation MILED  
 Size perforation 3.472  
 From 80 feet to 800' feet  
 From BEING PERF BLANK feet to PERF BLANK feet  
 From CAP ON BOTTOM OF feet to EAST POINT feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
X ENVIRO RING  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 100 feet below land surface  
 Artesian flow NO G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 90 °F Quality POOR

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WOYTEK DRILLING CO. INC. Contractor  
 Address 2720 STONE DRIVE Contractor  
RENO NEVADA 89511  
 Nevada contractor's license number issued by the State Contractor's Board 024521A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442  
 Signed Thomas M. Harris  
 By driller performing actual drilling on site or contractor  
 Date 9-24-98

Date started 9-16, 1998  
 Date completed 9-23, 1998

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>THIS WELL WHILE DRILLING ON AIR MADE @ 300 GPM</u>		