PW-24A

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73512
Permit No.
Basin 37

NOTICE OF INTENT NO.

1. OWNER AMAX Gold INC
MAILING ADDRESS 600 Sod House Rd
Winnemucca NV 89445
ADDRESS AT WELL LOCATION AMAX Sleeper Mine

2. LOCATION NE ¼ SW ¼ Sec. 21 T. 40 N/S R. 35 E. Humboldt County
PERMIT NO. 50390 (Issued by Water Resources) Parcel No. N/A (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Rip 2 Holes Every 2' From 135 up to 56' Run 2" Tremmie & Pump 10 Strength Mix To Surface & Run 20' & Pump Cement To Surface				
P&A				

Date started 8-14-97, 19
Date completed 8-14-97, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Plugging of log # 50600		

8. WELL CONSTRUCTION
Depth Drilled 704 Feet Depth Cased 700 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
26 Inches	0 Feet	704 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16	82.05	.250	-1	140

Perforations:
Type perforation Milled 3" x 1/8" Dbl. Std. Perfor
Size perforation Screen .50", .080" mild steel
From Perf 140 feet to 240 feet
From .050 Screen 240 feet to 400 feet
From .080 Screen 400 feet to 700 feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name STACO Well Services (Contractor)
Address 3359 Last Chance Rd (Contractor)
Elko NV 89801
Nevada contractor's license number issued by the State Contractor's Board 0038169
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2053
Signed (By driller performing actual drilling on site or contractor)
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627