

OFFICE USE ONLY  
 Log No. 73561  
 Permit No. \_\_\_\_\_  
 Basin 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32723

1. OWNER E. H. GROENENDYKE ADDRESS AT WELL LOCATION 551 FOOTBALL RD  
 MAILING ADDRESS 230 NEWPORT CENTER SUITE 300 NEWPORT BEACH, CA 92660 GV, NV 89410  
 2. LOCATION SW 1/4 NE 1/4 Sec 26 T 12 S R 19 E Douglas County  
 PERMIT NO. 19 29 29 Parcel No. NA Subdivision Name \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	2	2
SLIGHTLY CLAYEY SAND + V SMALL GRAVEL (DG)	X	2	8	6
MOSTLY DG SAND + SMALL GRAVEL W THIN CLAY BEDS	X	80	105	25
V COMPACT, SOLID DG, SOME FE STAINS, AB CLAY TO CLAYEY SAND + SMALL GRAVELS		105	140	35

HOLE PLUGGED W NEAT CEMENT FROM 110 TO 140 FT

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 110 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 Feet To 30 Feet  
 18 Inches  
 From 30 Feet To 140 Feet  
 14 Inches

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12 3/8		1/4	GL	30
8 7/8		.188	+2	110

Perforations:  
 Type perforation SAW CUT  
 Size perforation 3/16 x 3  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 90 feet to 110 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 90  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 110 feet to 90 feet

9. WATER LEVEL  
 Static water level + 20 feet ABOVE below land surface  
 Artesian flow + 30 G.P.M. P.S.I.  
 Water temperature COLD °F Quality ?

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name NEVADA DRILLING INC Contractor  
 Address 75 LEWERS CREEK RD Contractor  
WASHOE VALLEY, NV 89104  
 Nevada contractor's license number issued by the State Contractor's Board 13697A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790  
 Signed Joe Keiser  
 By driller performing actual drilling on site or contractor  
 Date 9/21/98

Date started 7/21 1998  
 Date completed 8/21 1998

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air-Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>100+</u>	<u>0</u>	<u>2</u>

RECEIVED  
 28 DEC - 8 AM 10:00  
 STATE ENGINEERING OFFICE