

WHITE-DIVISION OF WATER RESOURCES
 CANARY-CLIENT'S COPY
 PINK-WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 73608
 Permit No. 11579
 Basin 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17991

1. OWNER Flamingo Hilton ADDRESS AT WELL LOCATION 3555 Las Vegas Blvd. So.
 MAILING ADDRESS 3555 Las Vegas Blvd. So. Las Vegas, NV 89109

2. LOCATION SW 1/4 Sec. 16 T 21 N/S R 61 E Clark County Clark
 PERMIT NO. 11579 Issued by Water Resources Parcel No. 1621640100399 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill, caliche, white clay		0	52	52
Sand & clay		52	284	232
Gravel & sand		284	300	16
Brown clay w/some gravel		300	320	20
Brown clay		320	345	25
Gravel		345	355	10
Gravel, rocks, clay		355	365	10
Gravel		365	375	10
Gravel, clay		375	385	10
Clay		385	405	20
Sand		405	415	10
Cemented sand & gravel		415	425	10
Brown clay		425	445	20
Clay, sand, silt		445	455	10
Silty sand		455	465	10
Clay, Sand		465	475	10
Clay, slough mat.		475	485	10
Sand, clay		485	505	20
Sand, clay, gravel		505	515	10
Green clay		515	525	10
Silty sand		525	535	10
Green clay		535	545	10
Sand, clay		545	555	10
Silty clay		555	650	95
Clay		650	680	30
Silty sandy clay		680	700	20

8. WELL CONSTRUCTION
 Depth Drilled 890 Feet Depth Cased 890 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 50 Feet
 30 Inches 0 Feet 50 Feet
 22 Inches 50 Feet 890 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
24		.250	+0.5	50
12		.330	X+1	890

Perforations:
 Type perforation Johnson Hi-Cap Screen
 Size perforation .060
 From 300 feet to 420 feet
 From 490 feet to 550 feet
 From 690 feet to 870 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 0 feet to 890 feet

9. WATER LEVEL
 Static water level 86 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Thompson Drilling Co., Inc. Contractor
 Address 7227 Hauck Street Contractor
Las Vegas, NV 89118
 Nevada contractor's license number 4286A issued by the State Contractor's Board
 Nevada driller's license number issued by the 1735 Division of Water Resources, the on-site driller
 Signed Richard Thompson
 By driller performing actual drilling on site or contractor
 Date January 6, 1999

Date started October 20, 19 98
 Date completed December 30, 19 98

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
cont.	300	61	16

