

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16687

1. OWNER Holman ADDRESS AT WELL LOCATION 3610 S. Ravine  
MAILING ADDRESS 3610 S. Ravine Ave  
Reno, Nevada

2. LOCATION NW 1/4 SW 1/4 Sec. 35 T. 20 S N/S R. 53 E. County Nye  
PERMIT NO. 41-101-04 Calzada Valley Unit 3  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0	5'	5'
caliche		5'	20'	15'
caliche / clay		20'	30'	10'
clay		30'	80'	50'
caliche / clay		80'	100'	20'
caliche		100'	105'	5'
clay		105'	140'	35'

8. WELL CONSTRUCTION  
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)  
From To  
12 Inches 0 Feet 140 Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.625</u>	<u>4.33</u>	<u>.316</u>	<u>0'</u>	<u>140'</u>

Perforations:  
Type perforation Jaw cut  
Size perforation 1 7/8" x 3"  
From 100' feet to 140' feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50'  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 50' feet to 140' feet

9. WATER LEVEL  
Static water level: 25 feet below land surface  
Artesian flow: \_\_\_\_\_ G.P.M. P.S.I.  
Water temperature: \_\_\_\_\_ °F Quality: \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Tom Nailon Drilling Contractor  
Address Box 265 Reno, Nevada Contractor

Nevada contractor's license number 35704  
issued by the State Contractor's Board

Nevada driller's license number issued by the 1625T  
Division of Water Resources, the on-site driller

Signed Tom Nailon  
By driller performing actual drilling on site or contractor

Date 12/21/98

Date started Sept 20<sup>th</sup> 1998  
Date completed Sept 29<sup>th</sup> 1998

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)