

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18075

1. OWNER Badley Scattered Land and Equipment ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 3891 W. Donner 3891 W. Donner
Pahrump, NV 89048

2. LOCATION SW 1/4 NW 1/4 Sec. 10 T 20S N/S R 53E E Nye County
 PERMIT NO. 28-713-32 Charleston Park Ranchos
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Domestic
 Deepen Abandon Other Municipal/Industrial Irrigation Monitor Test Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown clay		0	5	5
white clay		5	11	6
grey clay		11	18	7
brown clay		18	29	11
grey clay		29	42	13
light brown clay		42	52	10
light grey clay		52	66	14
grey calache	x	66	95	29
light brown clay	x	95	117	22
grey calache	x	117	122	5
light green calache	x	122	140	18

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
 From To
11 Inches 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>3.7</u>	<u>.280</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation sawcut
 Size perforation .188
 From 110 feet to 140 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 66 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

Date started 11/1/98 _____ '98
 Date completed 11/1/98 _____ '98

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:	
	G.P.M.	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	Draw Down (Feet Below Static)	
<u>5</u>	<u>na</u>	<u>.50</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Strickland Construction Co., Inc. Contractor
 Address 2301 Winery Road, Suite 2 Contractor
Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board 40277
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
 Signed Larry Strickland
 By driller performing actual drilling on-site or contractor
 Date 11-18-98

DEC 24 1998

