

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18076

1. OWNER Badley Scattered Land and Equipment ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 3921 W. Donner 3921 W. Donner  
Pahrump, NV 89048

2. LOCATION SW 1/4 NW 1/4 Sec. 10 T 20S N/S R 53E E nye County \_\_\_\_\_  
 PERMIT NO. 28-713-34 Charleston Park Ranchos  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED 4. PROPOSED USE 5. WELL TYPE

X New Well  Replace  Recondition  Domestic  Irrigation  Test  Cable  Rotary  RVC  
 Deepen  Abandon  Other \_\_\_\_\_  Municipal/Industrial  Monitor  Stock  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown clay		0	5	5
white clay		5	12	7
grey clay		12	20	8
brown clay		20	29	9
grey clay		29	57	28
grey clay	x	57	74	17
light brown clay	x	74	77	3
light brown calache	x	77	115	38
grey calache	x	115	132	17
light green clay	x	132	140	8

8. WELL CONSTRUCTION

Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>11</u>	<u>0</u>	<u>140</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>3.7</u>	<u>.280</u>	<u>0</u>	<u>140</u>

Perforations:

Type perforation sawcut  
 Size perforation .188

From 110 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 50  Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured

Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

9. WATER LEVEL

Static water level 57 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. Contractor  
 Address 2301 Winery Road, Suite 2 Contractor  
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 40277  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086

Signed Larry Strickland  
 By driller performing actual drilling on-site or contractor  
 Date 11-18-98

Date started 11/1/98 19\_\_  
 Date completed 11/1/98 19\_\_

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:	
	G.P.M.	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
	Draw Down (Feet Below Static)	
<u>.5</u>	<u>na</u>	<u>.50</u>

DEC 24 1998

