WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73707
Permit No.
Basin 50

NOTICE OF INTENT NO. 36559

1. OWNER MIKE HASSITT
MAILING ADDRESS 1335 OAK ST
EIKO, NV 89801

ADDRESS AT WELL LOCATION LOT 5, BLOCK A

2. LOCATION SW ¼ NE ¼ Sec. 11 T. 35 N/S R. 54 E. EIKO County
PERMIT NO. (Issued by Water Resources) 005-52C-005 (Parcel No.) ADOBE RANCHES (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SUB SOIL		0	2	2
HARD PAN		2	4	2
CEMENTED GRAVEL		4	18	14
SANDSTONE		18	100	82
CLAY		100	106	6
CEMENTED GRAVEL		106	150	44
CLAY		150	158	8
CEMENTED GRAVEL		158	207	49
GRAVEL	X	207	209	2
GRAY CLAY		209	214	5
LIGHT BROWN CLAY		214	221	7
DARK BLACK SHALE		221	238	17
WHITE SANDSTONE		238	270	32
SOFT SANDSTONE	X	270	271	1
GREEN ROCK		271	280	9
DARK BROWN SHALE	X	280	284	4
FRACTURED				
CLAY		284	300	16
BROWN SHALE	X	300	312	12

RECEIVED
98 SEP -4 AM 10:38
STATE ENGINEERS OFFICE

Date started 7-24, 1998
Date completed 7-28, 19

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APROX.	30		3.5

8. WELL CONSTRUCTION
Depth Drilled 312 Feet Depth Cased 312 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	312 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	188	+2	312

Perforations:
Type perforation MILL SLOT
Size perforation 3/16" X 3"
From 292 feet to 312 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 54
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 54 feet to 312 feet

9. WATER LEVEL
Static water level 110 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name FERTIG DRILLING CO. (Contractor)
Address P.O. BOX 525 (Contractor)
EIKO, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 0031904

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584

Signed [signature]
By driller performing actual drilling on site or contractor

Date 8-18-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627