

OFFICE USE ONLY
 Log No. 73910
 Permit No. _____
 Basin 107

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 39041

1. OWNER Lyon Co. School Dist ADDRESS AT WELL LOCATION Smith Valley HS.
 MAILING ADDRESS 25 E. Goldfield #1 Day Lane Smith Valley NV

2. LOCATION SW 1/4 NW 1/4 Sec. 20 T. 11 N. R. 24 E Lyon County
 PERMIT NO. M/D 854 A Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG # 4

Material	Water Strata	From	To	Thick-ness
<u>2 Bag Cement</u>				
<u>Dropped center rods</u>	<u>6</u>			
<u>Down hole and</u>				
<u>Broke Bottom cap</u>				
<u>Granted from</u>				
<u>0-15'</u>				

8. WELL CONSTRUCTION
 Depth Drilled 15 Feet Depth Cased 15 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 15 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>	<u>PVC</u>	<u>SCH 40</u>	<u>0</u>	<u>15</u>

Perforations:
 Type perforation factory
 Size perforation 0.20

From 5 feet to 15 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 15 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 6 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality _____

Date started 9-18, 1998
 Date completed 9-18, 1998

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	<u>N/A</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Andresen Exploration Drilling
 Address 1635 Belford Rd Reno NV 89509
 Nevada contractor's license number 34525
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 1028 F-2
 Division of Water Resources, the on-site driller.
 Signed [Signature]
 Date 12/25/98

RECEIVED
 5:40 AM 12/15/98
 STATE ENGINEERS OFFICE