

OFFICE USE ONLY
 Log No. 73 Nel
 Permit No. 102
 Basin. 102

35081

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35081

1. OWNER Phil Calvert ADDRESS AT WELL LOCATION Blueberry Street
 MAILING ADDRESS 47 / Blueberry
 2. LOCATION NE 1/4 SE 1/4 Sec 10 T 17 N/S R 25 E Myon County
 PERMIT NO. 17-202-09 Parcel No. hakeside #5 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Clay</u>		<u>1</u>	<u>16</u>	
<u>Clay</u>		<u>16</u>	<u>36</u>	
<u>Clay</u>		<u>36</u>	<u>143</u>	
<u>Clay</u>	<u>160</u>	<u>143</u>	<u>160</u>	
<u>Gravel</u>	<u>174</u>	<u>160</u>	<u>174</u>	

8. WELL CONSTRUCTION
 Depth Drilled 174 Feet Depth Cased 175 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 174 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>1.88</u>	<u>1</u>	<u>174</u>

Perforations:
 Type perforation Iron Pipe
 Size perforation 5/16 x 1 1/2 x 6"
 From 164 feet to 172 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 75' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 27 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature C °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Earl Drill Inc Contractor
 Address 889 Contractor
88 NV 89409
 Nevada contractor's license number issued by the State Contractor's Board 0081821
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 9/10/98

Date started 9/1/98, 19____
 Date completed 9/3/98, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>65</u>		<u>23/4</u>

RECEIVED
 98 SEP 23 AM 10:27
 STATE ENGINEERS OFFICE