WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73973
Permit No.
Basin 105

NOTICE OF INTENT NO. 38854

1. OWNER Mark Garres
MAILING ADDRESS Stephenie Ln.
Gardnerville NV

ADDRESS AT WELL LOCATION 2655 Wade St.
Minden NV 89410

2. LOCATION NE ¼ SW ¼ Sec. 34 T. 14 N/S R. 20 E. Douglas County
PERMIT NO. (Issued by Water Resources) | Parcel No. 21-213-05 | Subdivision Name Johnson Lane

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Hard Rock		0	6	6
Course Gravels		6	29	23
Brown Clay		29	68	39
Hard Fractured Area		68	94	26
Solid Brown Clay		94	170	66
Fractured Gravels Obsidion Gravels Rusty Colored and Stained		170	180	10

RECEIVED 99 JAN -4 AM 9:18 STATE ENGINEER'S OFFICE

Date started 12-31, 19 98
Date completed 1-4, 19 99

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
18	45	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 180' Feet Depth Cased 180' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 1/4 Inches	0 Feet	180 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	180

Perforations:
Type perforation Mill Slot
Size perforation 3x3/32
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 180 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. 18 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPital City Well Drilling (Contractor)
Address 2d Kit KAT DR (Contractor)
Carson City NV. 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hall (By driller performing actual drilling on site or contractor)
Date 1-4-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627