WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73996
Permit No.
Basin 179

NOTICE OF INTENT NO. 33047

1. OWNER Reed R-Place Schell
MAILING ADDRESS 909 Avenue F
Ely, Nevada 89301

ADDRESS AT WELL LOCATION 909 Ave F, Ely NV 89301

2. LOCATION SE ¼ NW ¼ Sec. 16 T. 16 N/S R. 63 E. White Pine County
PERMIT NO. (Issued by Water Resources) 2-055-06 & 07 (Parcel No.) Well No. PMW-8 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	2	2
Gravel, Sand & Cobbles		2	5	3
Sandy Clay		5	22	17
Sand & Gravel		22	68	46
Silty Clayey Sands	x	68	80	12

RECEIVED 97 APR -3 AM 11:21 STATE ENGINEER'S OFFICE

Date started March 25, 1997
Date completed March 26, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A			

8. WELL CONSTRUCTION
Depth Drilled 80 Feet Depth Cased 80 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0 Feet	80 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	PVC	Schedule 40	0	80

Perforations:
Type perforation Screen
Size perforation 0.20 Slot
From 50 feet to 80 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 40
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Sand No3
Gravel Packed: ☒ Yes ☐ No 40' - 45' Bentonite Pelle
From 45 feet to 80 feet

9. WATER LEVEL
Static water level 68.82 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Murky

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Christiansen Drilling, Inc. (Contractor)
Address 557 Ely Avenue (Contractor)
Ely, NV 89301
Nevada contractor's license number issued by the State Contractor's Board 14790
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 641
Signed Jerold D. Christiansen (By driller performing actual drilling on site or contractor)
Date March 28, 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627