WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74032
Permit No.
Basin 212

NOTICE OF INTENT NO. 65569

1. OWNER Tab Contractors
MAILING ADDRESS 3617 N 5th
LV NV

ADDRESS AT WELL LOCATION On Frank
N. of N.V.

2. LOCATION ¼ E ¼ Sec. 5 T. 21 N/S R. 62 E. Clark County
PERMIT NO. DW 10992 (Issued by Water Resources) Parcel No. 161-05-710-036 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Bucket

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Fill Dirt & gravel | | 0 | 2 | 2 |
| Sandy Clays | | 2 | 12 | 10 |
| Fine-Med Sand | | 12 | 22 | 10 |
| Sandy Clays | | 22 | 40 | 18 |

Date started 10-4, 19
Date completed 10-4, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From (Feet) | To (Feet) |
|---|---|---|
| 24 | 0 | 40 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8 | PVC | Sch 40 | 0 | 40 |
| | | | | |

Perforations:
Type perforation Slot
Size perforation .003
From feet to feet
From 10 feet to 40 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From 0 feet to 40 feet

9. WATER LEVEL
Static water level 12 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CDC
Address 536 E Maitland (Contractor)
Ontario CA (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 31246
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1968
Signed (By driller performing actual drilling on site or contractor)
Date 10-24-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627