

OFFICE USE ONLY
 Log No. 7412
 Permit No. 13366
 Basin 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16221

1. OWNER CITY OF NORTH LAS VEGAS ADDRESS AT WELL LOCATION 304 E. TONOPAH - NORTH LAS VEGAS
 MAILING ADDRESS 2266 CIVIC CENTER DR
NORTH LAS VEGAS, NV 89030

2. LOCATION NE 1/4 SE 1/4 Sec. 22 T. 20 R. 61 E. County
 PERMIT NO. 13366 139-22-711-171 Subdivision Name
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>PULLED EXISTING 8" ANNA 55' @ 5'40'</u>				
<u>SOUNDED BOTTOM @ 890'</u>				
<u>BAILED BOTTOM TO 896'</u>				
<u>PUMPED NEAT CEMENT FROM 896' TO 420'</u>				
<u>USING 13 YARDS.</u>				
<u>PERFORATED CASING FROM 250' TO 85' USING</u>				
<u>MILLS KNIFE PERFORATOR</u>				
<u>PLACED GRAVEL FILL FROM 420' TO 430'</u>				
<u>PUMPED NEAT CEMENT FROM 430' TO</u>				
<u>8' USING 18 YARDS.</u>				
<u>CLEANED ANNULUS BETWEEN 14" CASING</u>				
<u>AND 30" CONDUIT DOWN TO 24'</u>				
<u>CLEANED 4" GRAVEL TUBES FROM</u>				
<u>SURFACE TO 24'</u>				
<u>PUMPED NEAT CEMENT FROM 8' TO 4'</u>				
<u>IN WELL AND FILLED 4-4" GRAVEL</u>				
<u>TUBES AND CONDUIT TO 4'</u>				
<u>CUT OFF CASING + GRAVEL TUBES +</u>				
<u>CONDUIT @ 4' BELOW SURFACE.</u>				
<u>BACKFILLED WITH TYPE II AND CURABLE.</u>				

8. WELL CONSTRUCTION
 Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations: PRIOR TO CEMENTING.
 Type perforation MILLS KNIFE
 Size perforation 12" X 2 1/2"

From 250' feet to 85' feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal _____
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 430' feet to 420' feet

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 2-1, 1999
 Date completed 3-1, 1999

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name B.L. WEAVER GROUP INC. Contractor
 Address 8108 Bay Harbor Drive
LAS VEGAS NV-89128 Contractor

Nevada contractor's license number issued by the State Contractor's Board 035639
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2078

Signed Davell Joseph
 By driller performing actual drilling on site or contractor

Date _____

