WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74113
Permit No.
Basin 212

NOTICE OF INTENT NO. 18615

1. OWNER Southland Corporation
MAILING ADDRESS 10220 SW Greenburg Rd #470 Portland, Oregon 97223
ADDRESS AT WELL LOCATION 600 North Las Vegas Blvd Las Vegas, Nevada

2. LOCATION SE ¼ SE ¼ Sec. 27 T. 20 N/S R. 61 E. Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. 139-27-305-002 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt, Fill sandy gravel light brown, slightly moist, no HC or HCS		0	2	
Clayey SAND, Med to coarse grain, greenish brown, very dense, slightly moist, some gravels, no HC or HCS		2	5	
Sand, medium to coarse grain, greenish-brown, very dense, slightly moist, some gravel, no HC or HCS, trace clay		5	9	
Caliche, highly cemented		9	18	
Clayey Sand, fine to medium grain, pale gray, medium dense, moist few gravels, HC, possible HCS		18	30	
TOTAL DEPTH 30 feet				

Date started 6-2, 19 91
Date completed 6-2, 19 91

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	30 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"			0	10

Perforations:
Type perforation Sch 40 PVC
Size perforation .020
From 10 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 9
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 9 feet to 30 feet

9. WATER LEVEL
Static water level 18 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Las Vegas Companies, Inc. (Contractor)
Address 301 W. Deer Valley Road #17 Phoenix, Arizona 85027 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 41309
Nevada driller's license number issued by the Division of Water Resources, the on site driller N2070
Signed (By driller performing actual drilling on site or contractor)
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627