

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35083

1. OWNER Robert M. Mangus & Associates ADDRESS AT WELL LOCATION 3780 E. 25th St Silver Springs, NV.
MAILING ADDRESS _____

2. LOCATION SE 1/4 SW 1/4 Sec. 16 T. 17 N/S R. 25 E Lyon County
PERMIT NO. PT-37-04 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Hand

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand</u>		<u>0</u>	<u>37</u>	
<u>Tan clay</u>		<u>37</u>	<u>62</u>	
<u>Gray clay</u>		<u>62</u>	<u>121</u>	
<u>Sand gravel</u>		<u>121</u>	<u>155</u>	
<u>Gray clay</u>		<u>155</u>	<u>203</u>	
<u>Gravel Boulder</u>		<u>203</u>	<u>240</u>	

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)
From 10 5/8 Inches To 7 1/2 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.00</u>	<u>3/16</u>	<u>7 1/2</u>	<u>240</u>

Perforations:
Type perforation Touch Cut
Size perforation 1 1/2 x 6.0 in. sprows
From 200 feet to 240 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 0-50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 50 feet to 240 feet

9. WATER LEVEL
Static water level 56 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

Date started 10-9 1998
Date completed 10-10 1998

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input checked="" type="checkbox"/> Air Lift
<u>50</u> G.P.M.			
	Draw Down (Feet Below Static)		Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Joseph Pulling Inc Contractor
Address 10 Box 549 Silver Springs NV 89429 Contractor
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources 1027 the on-site driller
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 10-10-98