X / +

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74142
Permit No.
Basin 031

NOTICE OF INTENT NO 28096

1. OWNER John Falen
MAILING ADDRESS OPOVADA, NV 89425
ADDRESS AT WELL LOCATION 10 miles South SR140 on Sod House Road

2. LOCATION SW ¼ SE ¼ Sec 7 T 39 N/S R 35 E Humboldt County
PERMIT NO. N/A (Issued by Water Resources) N/A (Parcel No.) Jackson Well ~~Subdivision~~ Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☒ Other Clean

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☒ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Take Down mill and Trip in hole with a 5 1/8" Bit Clean well 175' To 180 No H2O Drill From 180 To 200 Penetrated Another Aquifer At 186' Drill on To 200 Ft and Make a Reservoir Below Casing hole Still Caved into 186' put No Casing in Well Need mud To Do So.				
Static Water Level Raised To 132' From 186'				
Well Producing 50 gpm pumped Air For 6 hrs Cleaning Wind Blew With Magnum Force Almost Lost Wind mill Tower & pump Truck				

Date started 11-14, 1994
Date completed 11-30, 1994

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	Unknown	6 hrs

8. WELL CONSTRUCTION
Depth Drilled 180-200 Feet Depth Cased 180' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
5 1/8 Inches	180 Feet	200' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
Hole Caved in No Room For Casing				

Perforations:
Type perforation NA
Size perforation NA
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal NA
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From NA feet to NA feet

9. WATER LEVEL
Static water level 11-14-160' 11-30 132' feet below land surface
Artesian flow From 186' To 132 G.P.M. 50 23% P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson (Contractor)
Address 10760 Grass Valley Road (Contractor)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 024167
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 0375
Signed [signature] By driller performing actual drilling on site or contractor
Date 01-16-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627