

OFFICE USE ONLY
Log No. 74145
Permit No. _____
Basin 071

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28067

1. OWNER Cliff Burns ADDRESS AT WELL LOCATION _____
MAILING ADDRESS 2008 3rd St Sparks, NV 89431 650 LARK ST BIK D - Lot 8
2. LOCATION NW 1/4 Sec. 7 T. 34 S. R. 38 E. Dershing County
PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name Burns Acres

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
4. PROPOSED USE Domestic Municipal/Industrial Irrigation Monitor Test Stock
5. WELL TYPE Cable Air Rotary RVC Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY / silt		0	20	20
SAND / gravel		20	30	10
Fingered Lamers		30	60	30
SAND / gravel		60	100	40
SAND / gravel	X	100	110	10

8. WELL CONSTRUCTION
Depth Drilled 110 Feet Depth Cased 110 Feet
HOLE DIAMETER (BIT SIZE)
From 0 To 110
Inches _____ Feet _____
Inches _____ Feet _____
Inches _____ Feet _____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 5/8</u>	<u>12</u>	<u>1 3/8</u>	<u>0</u>	<u>110</u>

Perforations:
Type perforation Factory Cuts
Size perforation 3/32
From 90 feet to 110 feet
From _____ feet to _____ feet
Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
Depth of Seal 50
Placement Method: Pumped Poured
Gravel Packed: Yes No
From 50 feet to 110 feet

Date started 8-27, 1995
Date completed 8-28, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>	<u>N/A</u>	<u>1 hr</u>

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow NO G.P.M. N/A P.S.I.
Water temperature COOL °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name FRED ANDERSON Contractor
Address 10760 Grass Vly Winnemucca, NV Contractor
Nevada contractor's license number issued by the State Contractor's Board 0021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1375
Signed _____
Date 8-28-95

RECEIVED
25 DEC - 1 PM 2:28
STATE ENGINEERS OFFICE