WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74153
Permit No.
Basin 71

NOTICE OF INTENT NO. 36436

1. OWNER Darrell Beaths
MAILING ADDRESS 560 Beth Lane
Winnemucca, NV
ADDRESS AT WELL LOCATION 560 Beth Lane

2. LOCATION SW ¼ SW ¼ Sec. 32 T. 35 N/S R. 38 E. Humboldt County
PERMIT NO. (Issued by Water Resources) | Parcel No. 10-541-06 | Subdivision Name ZBS

3. WORK PERFORMED
☐ New Well ☑ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| | | | | |

Date started 6-1, 1996
Date completed 6-3, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 40 | N/A | 3 hr |

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10 5/8 | Inches | Feet | Feet |
| | Inches | Feet | Feet |
| | Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 12 | 188 | | |
| | | | | |

Perforations:
Type perforation Factory Cuts
Size perforation 3/32
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level ____ feet below land surface
Artesian flow No G.P.M. N/A P.S.I.
Water temperature 62.1 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson (Contractor)
Address 10760 Grass Valley (Contractor)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 21467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1375
Signed ____ (By driller performing actual drilling on site or contractor)
Date 6/11/96

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O) 627