



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31437

1. OWNER John Tallman ADDRESS AT WELL LOCATION 9355 Alice Lyne Winnemucca, NV  
 MAILING ADDRESS 9355 Alice Lyne Winnemucca, NV 89445 COUNTY Humboldt  
 2. LOCATION SW 1/4 Sec 30 T. 35 S. R. 38 E PERMIT NO. Domestic 10-533-24 Parcel No. \_\_\_\_\_ Subdivision Name ZBS  
 Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	1'	1
Large Rxs + Cobbles		94	1	95
SAND + Gravel		20	95	115
SAND Gravel + Clay 25%		11	115	126
3/4 + Gravel + SAND		69	126	195
Clay 30% SAND + Gravel		65	195	260

8. WELL CONSTRUCTION  
 Depth Drilled 260' Feet Depth Cased 260' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 260' Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>12</u>	<u>12</u>	<u>1.88</u>		

Perforations:  
 Type perforation Factory Cuts  
 Size perforation 3/32  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 260 feet

9. WATER LEVEL  
 Static water level 182 feet below land surface  
 Artesian flow NO G.P.M. N/A P.S.I.  
 Water temperature 62.1 °F Quality Good

Date started 6-4 1996  
 Date completed 6-8 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30</u>	<u>N/A</u>	<u>3HR</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Fred Anderson Contractor  
 Address 10760 Grass Valley Winnemucca, NV 89445 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 21467  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1375  
 Signed \_\_\_\_\_  
 By driller performing actual drilling on site or contractor  
 Date 6/11/96