

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33456

1. OWNER: Frank Smith ADDRESS AT WELL LOCATION: 4860 MAXINE DR  
 MAILING ADDRESS: 1724 SCOT ST Winnemucca, NV 89445  
 2. LOCATION: 1/4 SW 1/4 Sec 17 T 36 N 38 E Humboldt County  
 PERMIT NO. Domestic 10-202-26 Parcel No. Jones Subdivision Name

3. WORK PERFORMED:  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE:  Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE:  Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Topsoil		0	5	5
Sand + Rock		5	60	55
Gravel + Sand	Yes	60	70	10
Rock + Sand		70	140	70
Clay		140	160	20
Sand + Gravel	Yes	160	200	40

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 200 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 7/8 Inches To 0 Feet 200 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>10</u>	<u>1 3/8</u>	<u>+1</u>	<u>200</u>

Perforations:  
 Type perforation Factory Cut  
 Size perforation 3/32 x 4  
 From 160 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal 110  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 110 feet to 200 feet

9. WATER LEVEL  
 Static water level 147 feet below land surface  
 Artesian flow N/A G.P.M. 0/4 P.S.I.  
 Water temperature 60.1 °F Quality Fair

Date started July 7 1998  
 Date completed July 9 1998

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			<u>5</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Fred Anderson Drilling Contractor  
 Address 10760 Grass Valley Rd Contractor  
Winnemucca, NV  
 Nevada contractor's license number issued by the State Contractor's Board: 021467  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 2083  
 Signed Chris Klein  
 By driller performing actual drilling on site or contractor  
 Date July 17 98

RECEIVED  
 20 JUN 20 AM 9:59  
 STATE ENGINEERING OFFICE