WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340**

OFFICE USE ONLY
Log No. 74162
Permit No.
Basin 179

NOTICE OF INTENT NO. 33047

1. OWNER: Reed R-Place Shell
MAILING ADDRESS: 909 Avenue F, Ely, NV 89301
ADDRESS AT WELL LOCATION: 909 Ave F, Ely, NV 89301

2. LOCATION: SE ¼ NW ¼ Sec. 16 T 16 N/S R 63 E White Pine County
PERMIT NO. (Issued by Water Resources) 2-055-06 & 07 (Parcel No.) Well No. PMW-7 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Gravel | | 0 | 5 | 5 |
| Gravel Sand & Cobbles | | 5 | 20 | 15 |
| Sandy Clay | | 20 | 22 | 2 |
| Sand & Gravel | | 22 | 28 | 6 |
| Sandy Clay | | 28 | 66 | 38 |
| Gravel & Clay | x | 66 | 80 | 14 |

Date started March 25, 19 97
Date completed March 26, 19 97

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| N/A | | | |

8. WELL CONSTRUCTION
Depth Drilled 80 Feet Depth Cased 80 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 6 Inches | | 0 Feet | 80 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2 | PVC | Schedule 40 | 0 | 80 |

Perforations:
Type perforation: Screen
Size perforation: 0.20 Slot
From 50 feet to 80 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 40 ft
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Sand #3
Gravel Packed: ☒ Yes ☐ No 40' - 45' 3/8" Bentonite Pellets
From 45 feet to 80 feet

9. WATER LEVEL
Static water level 66.04 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Murky

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor): Christiansen Drilling, Inc.
Address (Contractor): 557 Ely Avenue, Ely, NV 89301
Nevada contractor's license number issued by the State Contractor's Board: 14790
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 641
Signed: Jerold D. Christiansen (By driller performing actual drilling on site or contractor)
Date: March 28, 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627