

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33444

1. OWNER Stacie M. Hee ADDRESS AT WELL LOCATION 8345 Hershell Road  
 MAILING ADDRESS 404 Acorn Court Winnemucca, NV 89445 Winnemucca

2. LOCATION SW 1/4 SE 1/4 Sec. 29 T. 35 N. R. 37 E Humboldt County Winnemucca  
 PERMIT NO. Domestic Issued by Water Resources 014-024-11 Parcel No. Grass Valley Nevada Sub # 5 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Topsoil</u>		<u>0</u>	<u>13</u>	<u>13</u>
<u>Clay</u>		<u>13</u>	<u>30</u>	<u>17</u>
<u>Sand + Gravel</u>		<u>30</u>	<u>60</u>	<u>30</u>
<u>Clay</u>		<u>60</u>	<u>70</u>	<u>10</u>
<u>Gravel</u>		<u>70</u>	<u>100</u>	<u>30</u>

8. WELL CONSTRUCTION  
 Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)  
 From 0 To 100  
10 5/8 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>10</u>	<u>1 3/8</u>	<u>1</u>	

Perforations:  
 Type perforation Factory cut  
 Size perforation 3/32 x 14  
 From 80 feet to 100 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 70'  Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured

Gravel Packed:  Yes  No  
 From 70 feet to 100 feet

RECEIVED  
 99 JAN 20 AM 9:59  
 STATE ENGINEERING BOARD

Date started OCT 5, 1998  
 Date completed OCT 7, 1998

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
		<u>4</u>

9. WATER LEVEL  
 Static water level 60 feet below land surface  
 Artesian flow N/A G.P.M. N/A P.S.I.  
 Water temperature 62.1 °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Fred Anderson Drilling, Inc Contractor  
 Address 10760 Grass Valley Rd Contractor  
Winnemucca, NV 89445  
 Nevada contractor's license number issued by the State Contractor's Board 021467  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083  
 Signed Chris Klatt  
 By driller performing actual drilling on site or contractor  
 Date OCT 29 1998