WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74177
Permit No. 217
Basin 67
NOTICE OF INTENT NO. 39826

1. OWNER City of Reno
MAILING ADDRESS P.O. Box 1990
Reno, NV 89505

ADDRESS AT WELL LOCATION
SE corner of 1st & Sierra St. Reno, NV

2. LOCATION NW 1/4 SE 1/4 Sec. 11 T 19N N/S R 19E E Washoe County
PERMIT NO. _____ Issued by Water Resources
11-111-24 Parcel No.
Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other _____

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we abandoned the 2" pvc sch 40 well. We pulled the casing out and pumped about 3 cu. ft of neat cement by tremie tube from bottom to top using pressure grout machine. We pumped the grout as we pulled the casing out. We punctured the bottom 2" pvc cap to get out the bottom with our tremie pipe.				

RECEIVED
98 DEC 23 AM 10:52
STATE ENGINEER'S OFFICE

Date started 12/8/98 , 19__
Date completed 12/8/98 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled _____ Feet Depth Cased 24 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
_____ Inches	_____ Feet	_____ Feet
_____ Inches	_____ Feet	_____ Feet
_____ Inches	_____ Feet	_____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	Sch 40		0	24

Perforations:
Type perforation Factory
Size perforation Screen .020
From 7 feet to 24 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal _____
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 9 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce MacKay Pump & Well Service, Inc. Contractor
Address 1600 Mt. Rose Hwy Contractor
RENO, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay
By driller performing actual drilling on site or contractor
Date 12-8-98