

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23 836

1. OWNER Newmont Gold Co. Lonetree ADDRESS AT WELL LOCATION Newmont Gold Co. Lone tree mine, P.O. Box 388 Valmy, NV, 89438
 MAILING ADDRESS Lonetree complex P.O. Box 388 Valmy NV 89438
 2. LOCATION NW 1/4 NE 1/4 Sec 29 T. 33 N/S R. 42 E Humbolt County
 PERMIT NO. N/A Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Alluvium	None	0	310	310
Alluvium		310	685	375
Siltstone		685	905	220
Sandstone		905	1000	95
Neat cement		0	55	55
Hole plug		55	70	15
Abandonite		70	710	640
#8 sand		710	830	120
Cement		830	1000	170

8. WELL CONSTRUCTION
 Depth Drilled 1000 Feet Depth Cased 830' Feet
 HOLE DIAMETER (BIT SIZE)
 From To
11 Inches 0 Feet 40 Feet
6.5 Inches 40 Feet 1000 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
7		.188	0+1	40
2.5	Sch 80	PVC	0+2	1000

Perforations:
 Type perforation 2.5" PVC Sch 80 screen
 Size perforation .210
 From _____ feet to _____ feet
 From 730 feet to 770 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 55' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 710 feet to 830 feet

9. WATER LEVEL
 Static water level 279 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 67 °F Quality clean

Date started 10-13, 1998
 Date completed 10-17, 1998

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>10</u>		<u>4 hours</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Eklund Drilling Co., Inc.
 Address P. O. Box 2748 Elko, NV 89803
 Nevada contractor's license number issued by the State Contractor's Board 0030823
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1861
 Signed Paul Mikelson
 By driller performing actual drilling on site or contractor
 Date 10-23-98