

OFFICE USE ONLY
 Log No. 74311
 Permit No. _____
 Basin _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27887

1. OWNER Charles Wiltsie ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 605 Calle De La Plata 603 Calle De La Plata
Sparks, Nevada 89436 Sparks, Nevada 89436
 2. LOCATION SW 1/4 SW 1/4 Sec. 17 T. 21N N/S R. 20 E Washoe County
 PERMIT NO. 076-690-66 Spanish Springs
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	2
Brown clay with decomposed granite		2	9	7
Weathered granite		9	18	9
White hard granite		18	80	62
Yellow clay		80	81	1
White granite		81	94	13
Gray granite		94	141	47
White granite		141	185	44
Gray granite		185	214	29
Rusty weathered granite		214	259	45
White hard granite		259	380	121
Fracture (NO WATER)		380	381	1
White hard granite		381	461	80
Soft zone (NO WATER)		461	464	3
White granite		464	530	66
Fracture granite	X	530	582	52
Gray granite		582	600	8

8. WELL CONSTRUCTION
 Depth Drilled 600 Feet Depth Cased 600 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 5/8 Inches 50 Feet 600 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	600

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 535 feet to 595 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 600 feet

9. WATER LEVEL
 Static water level 445 feet below land surface
 Artesian flow _____ G.P.M. 15 P.S.I.
 Water temperature cold °F Quality clear

Date started 9-29-98, 19____
 Date completed 10-06-98, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>15</u>		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number 0022549
 issued by the State Contractor's Board
 Nevada driller's license number 923
 issued by the Division of Water Resources, the on-site driller
 Signed Jerry C. Hedman
 By driller performing actual drilling on site or contractor
 Date October 8, 1998