

OFFICE USE ONLY
 Log No. 74212
 Permit No. 923
 Basin 3



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

25-CPD

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37880

1. OWNER MARK HILDERBRAND/J&L BUILDERS ADDRESS AT WELL LOCATION 9310 Matterhorn Blvd.
 MAILING ADDRESS P.O. Box 10798 Reno, Nevada 89506
 2. LOCATION NWSE 1/4 NWSE 1/4 Sec. 2726 T 22N N/S R. 19 E Washoe County Washoe
 PERMIT NO. 079-450-4780 Antelope Valley 314 feet
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Decomposed granite sands, w/brown clay		1	9	8
Brown sand		9	11	2
Decomposed granite sands w/brown clay		11	39	28
Decomposed granite sands		39	47	8
Brown sandy clay		47	140	93
Soft zone, fine to med sand (app 5 GPM)	X	140	146	6
Brown clay		146	155	9
Weathered granite		155	238	83
Fracture (app 10 GPM)	X	238	239	1
Weathered granite		239	250	11

8. WELL CONSTRUCTION
 Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 5/8 Inches 50 Feet 250 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	250

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 140 feet to 160 feet
 From 220 feet to 240 feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 feet Neat Cement
 Cement Grout
 Placement Method: Pumped Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 250 feet

9. WATER LEVEL
 Static water level 117 feet below land surface
 Artesian flow 15 G.P.M. 15 P.S.I.
 Water temperature cold °F Quality clear

Date started 9-24-98, 19
 Date completed 9-25-98, 19

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 0022549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed Wayne Drilling
 By driller performing actual drilling on site or contractor
 Date September 28, 1998