

OFFICE USE ONLY
 Log No. 74217
 Permit No. 93
 Basin

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 40374

1. OWNER JEFF ROBINSON ADDRESS AT WELL LOCATION 30 Filer Road
 MAILING ADDRESS 5940 Silverlake Road, #26 Reno, Nevada 89506
 2. LOCATION SE 1/4 SE 1/4 Sec. 23 T 22N N/S R 19 E Washoe County
 PERMIT NO. 079-470-58 Antelope Valley Red Rock Estates # 269
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other
 4. PROPOSED USE Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	2	2
Soft sandy clay		2	14	12
BRown sandy clay		14	70	56
Brown sand		70	72	2
Brown sandy clay		72	118	46
Yellowish brown sandy clay		118	144	26
Dark brown sandy clay		144	152	8
Soft zone (NO WATER)		152	154	2
Brown sandy clay		154	178	24
Soft zone	X	178	181	3
Brown sandy clay		181	207	26
Soft zone (NO WATER)		207	209	2
Gray rilite rock		209	255	46
Fracture rock	X	255	275	20

8. WELL CONSTRUCTION
 Depth Drilled 275 Feet Depth Cased 275 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 275 Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	275

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 175 feet to 195 feet
 From 255 feet to 275 feet
 Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 50 feet
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 275 feet

9. WATER LEVEL
 Static water level 105 feet below land surface
 Artesian flow 25+ G.P.M. P.S.I.
 Water temperature cold °F Quality clear

Date started 10-26-98, 19
 Date completed 10-27-98, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25+</u>		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 0022549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed By driller performing actual drilling on site or contractor
 Date October 28, 1998