

OFFICE USE ONLY  
 Log No. 74214  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37870

1. OWNER JOHN VEGH ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 155 Buckboard Cir. Same  
Reno, Nevada 89506  
 2. LOCATION SW 1/4 SW 1/4 Sec. 2 T 23N N/S R 18E E Washoe County  
 PERMIT NO. 078-241-03 Ranch Haven  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  Cable  Rotary  RVC  Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	2
Brown sandy clay		2	12	10
Gray sandy clay		12	49	37
Gray clay		49	88	39
Soft zone (med to fine sands)	X	88	123	35
Gray clay		123	130	7
Soft zone (med sands)	X	130	136	6
Gray clay		136	138	2
Soft zone (med sands)	X	138	151	13
Gray clay		151	155	4
Soft zone (med sands)	X	155	163	8
Gray clay		163	164	1

8. WELL CONSTRUCTION  
 Depth Drilled 164 Feet Depth Cased 164 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
9 7/8 Inches 0 Feet 164 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	164

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 5 around  
 From 116 feet to 156 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal 50 foot  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 164 feet

9. WATER LEVEL  
 Static water level 0 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 25+ P.S.I.  
 Water temperature cold °F Quality clear

Date started 10-30-98, 19\_\_\_\_  
 Date completed 11-03-98, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+		

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WAYNE DRILLING, INC. Contractor  
 Address P.O. BOX 12370 Contractor  
RENO, NEVADA 89510  
 Nevada contractor's license number issued by the State Contractor's Board 0022549  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923  
 Signed [Signature] by driller performing actual drilling on site or contractor  
 Date November 6, 1998