WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74217
Permit No.
Basin 103

NOTICE OF INTENT NO. 33730

1. OWNER Steve Kelly The General Store
MAILING ADDRESS 12000 US Hwy 50 E Mound house NV
ADDRESS AT WELL LOCATION SAME

2. LOCATION NE ¼ SW ¼ Sec. 29 T. 16 N/S R. 21 E. Lyon County
PERMIT NO. M.O. 746 (Issued by Water Resources) 016-194-14 (Parcel No.) 99983 (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Dry hole to Bfm 45' measured				
Filled hole from 45' to 20' with 3/8 Hole plug with 1 gal water every 5'.				
Filled hole with neat cement 2% bentonite from 20' to surface.				
Poured 1' redimix cap in manhole				
Owner to remove manhole when new asphalt is layed.				

RECEIVED 98 OCT -1 AM 10:38 STATE ENGINEER'S OFFICE

Date started 9-18, 1998
Date completed 9-18, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

8. WELL CONSTRUCTION
Depth Drilled 45 Feet Depth Cased 45 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	45 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4	SCH. 40	PVC	0	45

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 30 feet to 45 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 27'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 27 feet to 45 feet

9. WATER LEVEL
Static water level NO WATER ENCOUNTERED feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature — °F Quality —

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear Co (Contractor)
Address P.O. Box 1000 (Contractor)
Dayton NV. 89403
Nevada contractor's license number issued by the State Contractor's Board 0010157
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2050
Signed Roger K Magee (By driller performing actual drilling on site or contractor)
Date 9-18-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627