

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 74231
 Permit No. 6394
 Basin 101

NOTICE OF INTENT NO. 401

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Gary Laca ADDRESS AT WELL LOCATION 2258 Reno Hwy, Fallon, NV 89406
 MAILING ADDRESS 4700 Conrad Place
Fallon, NV 89406

2. LOCATION SW 1/4 SE 1/4 Sec. 26 T 19N N/S R 28E E Churchill County
 PERMIT NO. 63941 Parcel No. 008-361-2542 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sand		0	18	18
Brown Clay		18	22	4
Brown Sand		22	30	8
Gray sand		30	32	2
Brown Sand		32	41	9
Brown Clay		41	47	6
Gray Sand		47	72	25
Gray Clay		72	76	4
Brown Clay		76	83	7
Brown sand	XX	83	103	20

Plugged under NDI 62675

N39,477303
*W 118,804294 NAD27 * See plugging Log 109590*

RECEIVED
 99 JAN 22 AM 10:11
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 103 Feet Depth Cased 103 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 103 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	14.96	.188	0	10
6 5/8PVC	3.92	.250	0	103

Perforations:
 Type perforation Saw Cut
 Size perforation 1/8

From 100 feet to 103 feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 100 feet to 103 feet

Date started 12/30/98, 19__
 Date completed 12/30/98, 19__

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Baller <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30</u>		<u>1 hr.</u>

9. WATER LEVEL
 Static water level 9'6" feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. Contractor
 Address P.O. Box 1265 Contractor
Fallon, NV 89406

Nevada contractor's license number issued by the State Contractor's Board 29064
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 1-11-99