WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74232
Permit No.
Basin

NOTICE OF INTENT NO. 40110

1. OWNER Gary Laca
MAILING ADDRESS 4700 Conrad Place
Fallon, NV 89406

ADDRESS AT WELL LOCATION
2190 Reno Hwy, Fallon, NV 89406

2. LOCATION NE 1/4 NE 1/4 Sec. 35 T 19N N/S R 28E E Churchill County
PERMIT NO. (Issued by Water Resources) 08-361-26 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	18	18
Brown CLay		18	22	4
Brown Sand		22	30	8
Gray Sand		30	32	2
Brown Sand		32	41	9
Brown Clay		41	47	6
Gray Sand		47	72	25
Gray Clay		72	77	5
Brown CLay		77	85	8
Brown Sand	XX	85	103	18

RECEIVED 99 JAN 22 AM 10:11 STATE ENGINEER'S OFFICE

Date started 12/29/98, 19__
Date completed 12/29/98, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 103 Feet Depth Cased 103 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	103	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	14.96.	.188	0	10
6 PVC	3.92	.258	0	103

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 100 feet to 103 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 103 feet

9. WATER LEVEL
Static water level 9'6" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89406

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed Wayne Parsons
By driller performing actual drilling on-site or contractor

Date 1-11-99